

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-1591:206 Page 1 of 1

CATEGORY: Annunciators

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

DESIGN: Models QSA remote annunciator cabinets; Model RAI remote annunciator interface, followed by -1 or -2, followed by -F or -S. Stands for 1 or 2 zone, Surface or Flush mount and includes RAI.
*Models QSA key locked annunciator enclosures, followed by -1 or -2, followed by -F or -S, followed by -VR. Stands for 1 or 2 zone, Surface or Flush mount and VR stands for key locked. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as annunciators for use with listee's separately listed Models QSC, -QS1 and -QS4 (CSFM Listing No. 7165-1591:207) fire alarm control units. Refer to listee's Installation Instruction Manual for details.

NOTE: Formerly 7120-1388:236

*Rev. 05-10-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

MAY 10, 2004

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager